## Data sheet 6AV6642-0BC01-1AX1

\*\*\* spare part \*\*\* more information under SIMATIC news entry ID: 109486162. SIMATIC TP 177B 6" DP blue mode STN display MPI/PROFIBUS DP protocol RS485/RS422/USB interface printer interface slot for MMC configurable with WinCC flexible 2005



General information	
Product type designation	TP177B 6" DP Blue Mode
Customer-specific configuration	Yes
Display	
Design of display	STN
Screen diagonal	5.7 in
Color display	No
Number of colors	4; Blue levels
Resolution (pixels)	
<ul> <li>Horizontal image resolution</li> </ul>	320 pixel
<ul> <li>Vertical image resolution</li> </ul>	240 pixel
Backlighting	
<ul> <li>MTBF backlighting (at 25 °C)</li> </ul>	50 000 h
Control elements	
Control elements	Touch screen
Keyboard fonts	
System keys	Yes
<ul> <li>Numeric keyboard</li> </ul>	Yes
<ul> <li>alphanumeric keyboard</li> </ul>	Yes
<ul> <li>hexadecimal keyboard</li> </ul>	Yes
Multi-key operation	No
Touch operation	
Design as touch screen	Yes; analog, resistive
Connection type	
<ul> <li>Type of connection for mouse/keyboard/barcode reader</li> </ul>	USB / USB / USB
Installation type/mounting	
Mounting position	vertical
maximum permissible angle of inclination without external ventilation	35°
Supply voltage	
Type of supply voltage	DC
Input current	
Current consumption (rated value)	0.24 A
Starting current inrush I²t	0.5 A²·s
Processor	
Processor type	ARM, 200 MHz
Memory	
Type of memory	Flash / RAM
Memory available for user data	2 048 kbyte
Time of day	

Clock	
• Type	Hardware clock, synchronizable, no battery backup
• retentive	No
• synchronizable	Yes
Interfaces	
Interfaces/bus type	RS 232 optional, 1x RS 422, 1x RS 485 (max. 12 Mbit/s)
Number of industrial Ethernet interfaces	0
Number of RS 485 interfaces	1
Number of RS 422 interfaces	1
Number of USB interfaces	1; Up to 1 GB
PC card slot	No
CF card slot	No
Multimedia card/SD card slot	combined, from E-status 016 in connection with WinCC flexible 2008 SP1,
	MMC max. 128 MB / SD max. 512 MB
With software interfaces	No
Protocols	
Supports protocol for PROFINET IO	No
PROFIsafe	No
PROFIBUS	Yes
EtherNet/IP	Yes
Protocols (Ethernet)	
• TCP/IP	Yes
Protocols (terminal link)	
Sm@rtServer	Yes
Further protocols	
• MODBUS	Yes
Degree and class of protection	
IP (at the front)	IP65
IP (rear)	IP20
NEMA (front)	NEMA 4x, NEMA 12 (when installed)
Standards, approvals, certificates	
CE mark	Yes
UL approval	Yes
cULus	Yes
EAC (formerly Gost-R)	No
Suitable for safety functions	No
Use in hazardous areas	
ATEX Zone 2	No; certificate no longer available as of 1 October 2020
ATEX Zone 22	No; certificate no longer available as of 1 October 2020
FM Class I Division 2	Yes
Marine approval	
Germanischer Lloyd (GL)	Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)!
Germanischer Lloyd (GL)	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in
<ul><li>Germanischer Lloyd (GL)</li><li>American Bureau of Shipping (ABS)</li></ul>	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in
<ul> <li>Germanischer Lloyd (GL)</li> <li>American Bureau of Shipping (ABS)</li> <li>Bureau Veritas (BV)</li> </ul>	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in
<ul> <li>Germanischer Lloyd (GL)</li> <li>American Bureau of Shipping (ABS)</li> <li>Bureau Veritas (BV)</li> <li>Det Norske Veritas (DNV)</li> </ul>	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)!
<ul> <li>Germanischer Lloyd (GL)</li> <li>American Bureau of Shipping (ABS)</li> <li>Bureau Veritas (BV)</li> <li>Det Norske Veritas (DNV)</li> <li>Lloyds Register of Shipping (LRS)</li> </ul>	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!
<ul> <li>Germanischer Lloyd (GL)</li> <li>American Bureau of Shipping (ABS)</li> <li>Bureau Veritas (BV)</li> <li>Det Norske Veritas (DNV)</li> <li>Lloyds Register of Shipping (LRS)</li> <li>Polski Rejestr Statkow (PRS)</li> </ul>	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!
Germanischer Lloyd (GL)      American Bureau of Shipping (ABS)      Bureau Veritas (BV)      Det Norske Veritas (DNV)      Lloyds Register of Shipping (LRS)      Polski Rejestr Statkow (PRS)  Ambient conditions	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!
Germanischer Lloyd (GL)     American Bureau of Shipping (ABS)     Bureau Veritas (BV)     Det Norske Veritas (DNV)     Lloyds Register of Shipping (LRS)     Polski Rejestr Statkow (PRS)  Ambient conditions  Ambient temperature during operation	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!
Germanischer Lloyd (GL)     American Bureau of Shipping (ABS)     Bureau Veritas (BV)     Det Norske Veritas (DNV)     Lloyds Register of Shipping (LRS)     Polski Rejestr Statkow (PRS)  Ambient conditions  Ambient temperature during operation     min.	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!
Germanischer Lloyd (GL)  American Bureau of Shipping (ABS)  Bureau Veritas (BV)  Det Norske Veritas (DNV)  Lloyds Register of Shipping (LRS)  Polski Rejestr Statkow (PRS)  Ambient conditions  Ambient temperature during operation  min. max.	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!
Germanischer Lloyd (GL)     American Bureau of Shipping (ABS)     Bureau Veritas (BV)     Det Norske Veritas (DNV)     Lloyds Register of Shipping (LRS)     Polski Rejestr Statkow (PRS)  Ambient conditions  Ambient temperature during operation     min.     max.  Ambient temperature during storage/transportation	SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)! No; only valid up to and including the HW release (see MLFB release notes in SIOS)!  0 °C 50 °C
Germanischer Lloyd (GL)  American Bureau of Shipping (ABS)  Bureau Veritas (BV)  Det Norske Veritas (DNV)  Lloyds Register of Shipping (LRS)  Polski Rejestr Statkow (PRS)  Ambient conditions  Ambient temperature during operation  min.  max.  Ambient temperature during storage/transportation  min.	SIOS)!  Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)!  Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)!  Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)!  Yes; only valid up to and including the HW release (see MLFB release notes in SIOS)!  No; only valid up to and including the HW release (see MLFB release notes in SIOS)!  0 °C  50 °C

Operating systems	
pre-installed operating system	Windows CE
configuration / header	
Message indicator	Yes
Alarm system (incl. buffer and acknowledgment)	Yes
Process value display (output)	Yes
Process value default (input) possible	Yes
Recipe management	Yes
Configuration software	
Configuration tool	WinCC flexible Compact Version 2005 or higher (to be ordered separately)
STEP 7 Basic (TIA Portal)	No
STEP 7 Professional (TIA Portal)	No
WinCC flexible Compact	Yes
WinCC flexible Standard	Yes
WinCC flexible Advanced	Yes
WinCC Basic (TIA Portal)	No
WinCC Comfort (TIA Portal)	Yes
WinCC Advanced (TIA Portal)	Yes
WinCC Professional (TIA Portal)	Yes
Languages	
Online languages	
Number of online/runtime languages	5
Project languages	
Languages per project	32
Functionality under WinCC (TIA Portal)	
Libraries	Yes
Task planner	Yes
Help system	Yes
Number of characters per info text	70
Message system	
Number of alarm classes	32
Number of messages	2 000
Bit messages	Yes
<ul> <li>Number of bit messages</li> </ul>	2 000
Analog messages	Yes
<ul> <li>Number of analog messages</li> </ul>	50
Telegram message procedure Alarm S	No
System messages HMI	Yes
System messages PLC	Yes
<ul> <li>System event, more (SIMATIC S7, SINUMERIK, SIMOTION,)</li> </ul>	No
• Lines	1
Number of characters per message	80
Number of process values per message	8
Acknowledgment groups	
Number of acknowledgement groups	99
Message indicator	Yes
acoustic feedback	No
First/last value	Yes
Recipe management	
Number of recipes	100
Data records per recipe	200
Entries per data record	200
Recipe memory	32 KB integrated Flash, expandable
Variables	
Variables  ■ Number of variables per device	1 000
	1 000 50
Number of variables per device	
<ul><li>Number of variables per device</li><li>Number of variables per screen</li></ul>	50
<ul><li>Number of variables per device</li><li>Number of variables per screen</li><li>Number of variables</li></ul>	50 1 000

Multiplexing	Yes
Multiplexing     Structures	No
• Structures Images	INU
Number of configurable images	500
Permanent window/default	Yes
	Yes
Start screen configurable     Image selection by DLC	Yes
Image number in the RI C	
Image number in the PLC	Yes
Image objects	0.500 tout alamanta
• Text objects	2 500 text elements
Number of I/O fields per image	50
Number of date/time fields	30
Index of screen context	No
• Return	Yes
Graphics object	Bit maps, icons, icon (full-screen), vector graphics
— Icons	500
— Icon (full screen)	50
Complex image objects	
Status/control	With SIMATIC S7
dynamic objects	Diagrams, bar graphs, sliders, analog display, invisible buttons
<ul> <li>Number of objects per project</li> </ul>	500
<ul> <li>Number of curve diagrams per image</li> </ul>	5
<ul><li>Methods</li></ul>	Trend
Bar graphs	
<ul> <li>Number of bars per chart</li> </ul>	5
<ul> <li>Sliders</li> </ul>	
<ul> <li>Number of slides per image</li> </ul>	0
Pointer instruments	
<ul> <li>Number of analog indicators per image</li> </ul>	0
Limit value lines	Yes
<ul> <li>Number of alphanumerical fields</li> </ul>	1 000
— alphanumeric fields per image	100
Number of numerical fields	1 000
<ul> <li>numerical fields per image</li> </ul>	100
Number of password fields	1 000
Number of visible switches per project	1 000
visible switches per image	100
hidden switches per image	100
Number of status switches per project	1 000
Number of status switches per image	100
Number of status switches per image     Number of selector switches per project	1 000
,	100
Selector switches per image  Number of decade switches per project.	0
Number of decade switches per project      Decade switches per image.	
— Decade switches per image	0
Number of signal lamps per project	1 000
— Signal lamps per image	100
Attributes for dynamic objects	· ·
Color change	Yes
X/Y movement	Yes
• Hide	Yes
Angle of rotation	No
Lists	
<ul> <li>Number of text lists per project</li> </ul>	300
<ul> <li>Number of text lists per image</li> </ul>	10
<ul> <li>Number of entries per text list</li> </ul>	30
<ul> <li>Number of graphics lists per project</li> </ul>	100
<ul> <li>Number of graphic lists per image</li> </ul>	10
<ul> <li>Number of entries per graphics list</li> </ul>	30
Security	
Number of user groups	50
Number of user rights	32

<ul> <li>Password export/import</li> </ul>	Yes
Data carrier support	160
PC card	No
• CF card	No
Logging through printer	
Recording/Printing	Alarms, report (shift report), hardcopy
Transfer (upload/download)	
Transfer of configuration	MPI/PROFIBUS DP, serial, USB, by means of external storage medium,
	automatic transfer recognition
Process coupling	
Connection to controller	S5, S7-200, S7- 300/400, Win AC, SINUMERIK, SIMOTION, Allen Bradley (DF1), Mitsubishi (FX), Telemecanique (ADJUST), Modicon (Modbus), for further non-Siemens drivers, see section on "System interfaces"
• S7-1200	Yes
• S7-1500	No
• S7-200	Yes
— PPI (point-to-point)	Yes
— PPI network	No
— MPI	Yes
— PROFIBUS DP	Yes
— Ethernet	No
• S7-300/400	Yes
— MPI	Yes
— PROFIBUS DP	Yes
— PROFINET	No Voc. only PROFIBILE DR
• S5	Yes; only PROFIBUS DP No
— serial — PROFIBUS DP	
— PROFIBUS DP  ■ TI 505	Yes No
Allen Bradley (DF1)	Yes
Allen Bradley (DF1)     Allen Bradley (DF485)	Yes
Mitsubishi (FX)	Yes
Telemecanique (ADJUST)  • Telemecanique (ADJUST)	No
Telemecanique (Ni-Telway)  Telemecanique (Uni-Telway)	Yes; Only in combination with WinCC flexible
OMRON (LINK/Multilink)	Yes
Modicon (Modbus)	Yes
Functions	
Key repeat	No
TAB sequence	Yes
Calculating functions	Yes
Animate	Yes
Menu tree editor	Yes
Unit switchover	No
Service tools/configuration aids	
Clean screen	Yes
Touch calibration	Yes
<ul> <li>Backup/Restore manually</li> </ul>	Yes
<ul> <li>Simulation</li> </ul>	Yes
Device switchover	Yes
Delta transfer	Yes
<ul> <li>Monitoring function for battery and memory</li> </ul>	No
Trace (operation archive)	No
Expandability/openness	
Open Platform Program	Yes
Peripherals/Options	
Peripherals	Printer
SIMATIC HMI MM memory card: Multi Media Card	Yes
Additional software components loadable	Yes
Dimensions	
Width of the housing front	212 mm
Height of housing front	156 mm

Mounting cutout, width	198 mm
Mounting cutout, height	142 mm
Overall depth	44 mm
Weights	
Weight (without packaging)	0.8 kg
Other	
free hotline	Yes

last modified: 12/8/2024 🖸